



MODEL		TOP KFW - 18.2 GH				TOP KFW - 18.3 GH				TOP KFW - 18.4 GH				
Protok vazduha		1200 m <sup>3</sup> /h				900m <sup>3</sup> /h				850m <sup>3</sup> /h				
G/H	Režim vode	Tul. [°C]	Q [kW]	Tiz [°C]	Δp [kPa]	q <sub>w</sub> [m <sup>3</sup> /h]	Q [kW]	Tiz [°C]	Δp [kPa]	q <sub>w</sub> [m <sup>3</sup> /h]	Q [kW]	Tiz [°C]	Δp [kPa]	q <sub>w</sub> [m <sup>3</sup> /h]
H L A Đ E N J E	7/12°C	25(50%)	1.32	21.7	0.69	0.22	2.23	17.6	2.06	0.38	2.27	17.1	1.19	0.38
		27(47%)	1.91	22.3	1.21	0.32	2.65	18.2	2.74	0.45	2.81	17.1	1.66	0.47
		32(39%)	2.91	24.6	2.4	0.49	3.65	19.7	4.7	0.61	3.98	17.8	2.89	0.67
		35(33%)	3.47	26.1	3.21	0.58	4.21	20.7	6.01	0.71	4.64	18.3	3.7	0.78
	12/17°C	25(50%)	/	/	/	/	1.08	21.4	0.63	0.18	/	/	/	/
		27(47%)	/	/	/	/	1.68	21.4	1.27	0.28	/	/	/	/
		32(39%)	2.08	26.7	1.37	0.35	2.73	22.8	2.83	0.46	2.96	21.5	1.77	0.5
		35(33%)	2.66	28.2	2.04	0.45	3.32	23.7	3.92	0.56	3.63	21.9	2.45	0.61
G R E J A N J E	45/40°C	-15	9.38	8.3	16.98	1.63	10.45	19.7	28.16	1.82	11.72	26.2	17.06	2.04
		-10	8.52	11.2	14.3	1.48	9.5	21.5	23.77	1.65	10.66	27.4	14.47	1.85
		-5	7.65	14	11.84	1.33	8.56	23.4	19.72	1.49	9.6	28.7	12.08	1.67
		0	6.78	16.9	9.58	1.18	7.62	25.3	16.2	1.32	8.55	30	9.88	1.49
		5	5.91	19.7	7.55	1.03	6.67	27.1	12.68	1.16	7.49	31.3	7.88	1.3
		10	5.04	22.5	5.74	0.88	5.73	29	9.7	1	6.43	32.6	6.1	1.12
		15	4.17	25.4	4.16	0.73	4.78	30.9	7.08	0.83	5.37	33.8	4.51	0.93
		20	3.3	28.2	2.81	0.57	3.83	32.7	4.83	0.67	4.3	35.1	3.14	0.75
55/45°C	-15	10.17	10.3	5.76	0.89	11.52	23.2	9.65	1	12.93	30.4	6.08	1.13	
	-10	9.3	13.1	4.95	0.81	10.58	25.1	8.31	0.92	11.88	31.7	5.28	1.04	
	-5	8.43	16	4.19	0.74	9.63	26.9	7.06	0.84	10.82	33	4.52	0.94	
	0	7.56	18.8	3.49	0.66	8.68	28.8	5.9	0.76	9.75	34.3	3.81	0.85	
	5	6.69	21.6	2.84	0.58	7.74	30.7	4.84	0.67	8.68	35.5	3.15	0.76	
	10	5.81	24.5	2.26	0.51	6.79	32.5	3.87	0.59	7.61	36.7	2.55	0.66	
70/50°C	-15	10.97	12.3	2.02	0.48	12.77	27.4	3.43	0.56	14.34	35.4	2.29	0.63	
	-10	10.09	15.1	1.76	0.44	11.82	29.2	3.01	0.52	13.27	36.6	2.02	0.58	
	-5	9.21	17.9	1.52	0.4	10.87	31	2.62	0.48	12.19	37.8	1.77	0.53	
	0	8.33	20.7	1.30	0.36	9.91	32.9	2.24	0.43	11.11	39.0	1.53	0.49	
	5	7.44	23.5	1.09	0.33	8.95	34.7	1.89	0.39	10.02	40.2	1.31	0.44	
	10	6.55	26.3	0.89	0.29	7.98	36.5	1.57	0.35	8.92	41.3	1.10	0.39	
80/60°C	-15	12.88	17.1	2.60	0.57	14.78	34.0	4.34	0.65	16.63	43.4	2.87	0.73	
	-10	12.01	19.9	2.31	0.53	13.83	35.9	3.87	0.61	15.57	44.7	2.58	0.68	
	-5	11.14	22.7	2.05	0.49	12.88	37.7	3.43	0.57	14.5	45.9	2.3	0.64	
	0	10.26	25.5	1.79	0.45	11.94	39.6	3.02	0.52	13.42	47.2	2.04	0.59	
	5	9.38	28.3	1.55	0.41	10.99	41.5	2.63	0.48	12.35	48.4	1.79	0.54	
	10	8.51	31.2	1.33	0.37	10.03	43.3	2.26	0.44	11.27	49.4	1.55	0.50	
90/70°C	-15	14.77	21.7	3.22	0.65	16.78	40.7	5.31	0.74	18.88	51.3	3.48	0.83	
	-10	13.91	24.6	2.91	0.61	15.83	42.4	4.81	0.70	17.83	52.6	3.17	0.79	
	-5	13.03	27.4	2.62	0.57	14.88	44.4	4.33	0.66	16.76	53.9	2.87	0.74	
	0	12.16	30.2	2.33	0.54	13.94	46.2	3.87	0.62	15.70	55.1	2.58	0.69	
	5	11.28	33.1	2.07	0.5	12.99	48.1	3.43	0.57	14.63	56.4	2.31	0.65	
	10	10.41	35.9	1.81	0.46	12.05	50.0	3.02	0.53	13.56	57.6	2.05	0.60	
		15	9.54	38.7	1.57	0.42	11.09	51.8	2.63	0.49	12.48	58.8	1.80	0.55
		20	8.66	41.5	1.35	0.38	10.14	53.6	2.27	0.45	11.41	60.1	1.56	0.5